

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7150-1496:129 Page 1 of 1

**CATEGORY:** Boxes/Pull Stations

**LISTEE:** Firecom Inc., 39-27 59<sup>th</sup> Street, Woodside, NY 11377  
Contact: Howard Kogen (718) 899-6100 FAX (718) 899-1932

**DESIGN:** Models FSG-32AXK1, FSG-32AXK2, FSG-32SK1 and FSG-32SK2 noncoded manual pull stations. Suffix K indicating key lock, followed by suffix 1 (push bar) or 2 (no push bar). Suitable for outdoor use when installed with Model FSG-32WP back box. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 30 VDC

**INSTALLATION:** In accordance with listee's printed installation, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as manual pull stations for use with separately listed and compatible fire alarm control units.

**XLf:** 7150-1408:107

03-11-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager